

Design of High Rate Blender Hydraulic Power Pack Unit on Stimulation Vessel – Study Case Stim Star Borneo for Offshore Operations at Delta Mahakam Area – East Borneo

Hari Prastowo¹, Sutopo Purwono Fitri², Raja Oloan Saut Gurning³, Sahrul Abidin⁴

Abstract—currently application of hydraulic power technology in world industry is still increased. Those phenomenon not only in Industrial field but also in Marine, Onshore and Offshore that use these technologies. Requirement of service in Offshore Delta Mahakam region makes PT. Halliburton Indonesia as a Service Company increase his fleet service. One of the Type Stimulation Vessel Fleets - Stim Star Borneo is planned to improve the service unit of High Rate Water Pack (HRWP) with High Pressure Pump unit plus Gravel Pack Sand (GP) and High Rate Blender Unit as its tools. Blender High Rate is a unit tubular mixing blender driven by hydraulic power, motors blender, sand screw, pump suction and discharge pump that is installed as an unity. In order to analyze those installation, it needs to be planned the section of its system, calculation and specifications of Hydraulic Power Pack Unit for High Rate the Blender. Calculations start from the Operational Requirement Conditions, and continued with Design Block Diagram, P & ID, and also calculations of systems parameter such as Head, RPM, Pipe Diameter, Pipe Thickness, Main Hydraulic Pump, Reservoir Tank and Cooler. The Requirement of Hydraulic Main Pump Power is 950 kW with Electric Motor as prime mover 950 kW. The final result of the design is shown as Layout and Detail drawing in attachment.

Keywords — hydraulic, power pack, high rate blender, stim star borneo

I. INTRODUCTION

The application of technology Hydraulic Power Pack Unit in the industry today's world is continues to increase. Not only in Industrial alone, but also in Marine, Onshore and Offshore field use these technologies.

The growing demands for well servicing services - offshore Mahakam Delta region makes PT. Halliburton Indonesia as a Service Company increasing its fleet in the Production Enhancement (PE) Department. PE Department which has a fleet of Stimulation Vessel Type - Stim Star Borneo plan to improve the service unit of High Rate Water Pack (HRWP) with High

Pressure Pump unit plus Gravel Pack Sand (GP) with High Rate Blender Unit. Blender High Rate This is a unit that is tubular mixing blender is driven by hydraulic power, motors, sand screw, pump suction and discharge pump installed as one unit. High Rate Blender function is to rotate and mix the sand, water and chemicals in the form of a gel called gravel pack which will be pumped by High Pressure Pump to the Well. Rate of Blender where this should be able to generate a rate or debit corresponding services required Delta Mahakam area.

Hari Prastowo, Department of Marine Engineering, Institut Teknologi Sepuluh Nopember, Surabaya, 60111, Indonesia. Email: h-prastowo@its.ac.id

Sutopo Purwono Fitri, Department of Marine Engineering, Institut Teknologi Sepuluh Nopember, Surabaya, 60111, Indonesia. Email: sutopopf@gmail.com

Raja Oloan Saut Gurning, Department of Marine Engineering, Institut Teknologi Sepuluh Nopember, Surabaya, 60111, Indonesia. Email: sautg@its.ac.id

Sahrul Abidin, Department of Marine Engineering, Institut Teknologi Sepuluh Nopember, Surabaya, 60111, Indonesia. Email: -

In this research the system specifications Hydraulic Power Pack Unit for High Rate the Blender will be planned and calculated.

In this research the planning of the Hydraulic Power Pack Unit covers the systems, equipment and technical specifications in the form of Layout and Detail drawing.

II. METHOD

The methodology is to determine the objectives and measures of the research. The methodology serves as the main framework to be the determination of the discussion. The method used in this research is a mixed method which briefly shows: (1) identify the problem and research objectives, (2) search for data and literature supporting, (3) analyze and interpret data (4) create a design and report

2.1. Literatur Review

Literature is the first step in the research to look for references and materials to be used as reference material in accordance with the analysis that is reliable so as to help the research. The literature study can be taken from a reference source document or Data Operations, Engineering Books, Catalogs and related Journal. include: Primary Data Ship, Ship Specification Data and Operational Data Tools.

2.2. Data Analysis Operational Requirement

After data collection, data analysis performed for the calculation and determination of the operational condition in accordance with the data being before and is the next step to process the detailed data to assist the research. Data analysis and operational requirements were conducted to determine the parameters and operational requirements based on the data that has been collected previously in this research.



Figure.1. Stimulation Vessel - SSB




Figure.2. High Rate Blender Unit

2.3. Drafting Design Systems

Drafting Design System includes Block Diagram and P & ID diagrams. This is done because the calculation system and design should be consistent. Where the Block Diagram explaining the work process flow diagram Hydraulic Power Pack, which describes the unit - the unit that become manual hydraulic pump unit. While P & ID is a more specific system design that describes the flow or pipe system, instrument - instrument and unit - including the number of units and specifications as the reference for the calculation system.

2.4. Calculation system and Specifications

The Data Design / Draft from previous Design and Operational Requirement, needs to have the calculation of those system. Where the calculation of this system include:

- a) Calculation of Unit Head and RPM user
- b) Adjustment Calculation RPM Motor Hydraulic
- c) Calculation of Diameter Pipe Unit Users
- d) Calculation of Diameter Pipes Main Hydraulic Pump
- e) Calculation material and minimum thickness of pipe
- f) Calculation of Main Pump Head
- g) The need Hydraulic Main Pump
- h) Electric Motor Supplies (Driver)
- i) The need Reservoir Tank
- j) The need Cooler

2.5. Design Block Diagram, P & ID, Specifications System and Equipment

Search units available in the market in accordance with the specifications and catalog available.

2.6. Making Design Layout and Cost Analysis

System designs that already meet the requirement will be created its Design Layout plotted on the General Arrangement Stimulation Vessel - SSB in accordance with the specifications and the size of the catalog according to standard drawing. Then in doing analysis calculation installation costs.

2.7. Conclusions and recommendations

Conclusions and Recommendations are made based on all aspects of the discussion of this research.

III. RESULTS AND DISCUSSION

3.1 Operational Data and Design

Operational planning design Hydraulic Power Pack Unit is in accordance with the Regional Operational Delta Mahakam block in East Kalimantan. Data is obtained from PT. Total E & P Indonesia and PT. Halliburton Indonesia – Balikpapan, the process that could happen on the system are:

- a. **Fluid Mixing Process** : HRB is used to manufacture a mixture of gel fluid or process fluid
- b. **Circulating Mixing Process** : HRB is used on mixing fluid. In those process is inside fluid tanks and then return the pump to the process fluid tanks. This is done to maintain the mixture composition and process fluid in ideal conditions.
- c. **Direct Discharge or Direct Mixing Discharge** : ie unit Pump Suction and Discharge HRB used as a reservoir discharge path which is then directly connected to the suction pipe High Pressure Pump. On the other conditions are also designed HRB used in a condition to Tab Fluid

Mixing Blender then in mixing and pumped to the High Pressure Pump Suction pipe discharge

TABLE. 1.
 PUMPING SCHEDULE ZONE 1 DATA

Working Volume	Surfactant Volume	Volume to X-over	Volume to stop perfs	Volume to bit perfs
448 gal	138 gal	408 gal	498 gal	500 gal
105.7 bbl	3.0 bbl	105.7 bbl	118.7 bbl	119.2 bbl

Base fluid	Prepagent Bulk Density	Prepagent Volume Factor	Pressure Test	Tubing Pop Off	Set Pump Kick Out	Set Annulus Kickstart	Hydrostatic Pressure	Gravel Pac Displacement	Gravel Pac Displacement @ slowdown
8.998 gpg	87 lbs/IG	0.0449 gal/lbs	8,000 psi	5,000 psi	4,800 psi	3,900 psi	2,658 psi at top perf	5.0 bbls from x-over	from x-over

TOOL POSITIONS	PROCEDURE
Circulate Around screen into annulus- BOP open	Reverse Down Annulus - Up Tubing - BOP Open
Squeeze Down Tubing, BOP Closed	

Stage No.	Stage Type	Clean Vol. gals	Dry Vol. gals	Dry Vol. bbls	Sand Wt lbs	Rate bpm	Start Prop ppg	End Prop ppg	Stage Time mins	Fluid Type	Fluid at Perfs
1	Flush Lines & Test Line	7000	0	0	0	1.2			22.81	Completion Stage	Completion Stage
2	Circulate Test in weight down position	4,000	4,000	115	0	1.2			18.5	Completion Stage	Completion Stage
3	Shut-in - Move Tool to Squeeze Position	550	550	15	0	1.2			10.000 psi	30W HEC Breaker	30W HEC Breaker
4	Reverse 1/2 Annulus - Test	400	4,000	100	0	1.0-1.0			18.5	30W HEC Breaker	30W HEC Breaker
5	Stopin - Hold Shut Down - Monitor Pressure until copyright man or operator gives signal to continue	100	0	0	0	14.0	1.0	1.0	2.14	30W HEC Breaker	30W HEC Breaker
6	Stand Ladder Linear Lift	6,396	7,381	174	6,396	14.0	1.2	1.0	12.36	30W HEC Breaker	30W HEC Breaker
7	Displacement	4,396	4,396	105	0	14.0			7.48	Completion Stage	30W HEC Breaker

Of the three operational conditions above can be obtained following data:

TABLE. 2.
 OPERASIONAL REQUIREMENT

No	Equipment /User	Requirement	Unit
A	Fluid Mixing Process	Time per Mixing 1x cap.tube/min As designed 10.5 bbl/min Or 1670 Ltr/Min	bbl/min Ltr/min
1	Base Fluid ; LA Pump 1 / 2	200 ml/L x 1670 Lt 334 x 10 ³ ml = 334 Lt/min per pump	Ltr/min
2	pH Buffer (caustic) Dry Additive 1	0.1 ml/L x 1670 Lt 167 ml = 0.167 Lt/0.5min per pump Or 0.334 Ltr/min	Ltr/min
	pH Buffer (acid) Dry Additive 1	0.55 ml/L x 1670 Lt 918.5 ml = 0.9185 Lt/0.5min per pump Or 1.837 Ltr/Min	Ltr/min
3	Polymer / Sand Sand screw 1 / 2	2000 gr/L x 1670Lt = 167 x 10 ⁴ gr = 3681 gr/0.5min per screw Or 1840.5 gr/min	gr/min
4	Blender Turbin Agitator	Cap. 75-90 rev/min Input 90 rev/min	rev/min
B	Circulating Mixing Process	Every 20 minute	
5	Suction Centrifugal Pump Max. Flow rate 100 bbl/min	Cap. Tank/time 649 bbls/20 min 32.45 bbl/min Or 5.192 m ³ /min	bbl/min m ³ /min
6	Discharge Centrifugal Pump Flow Rate 24 bbl/min at 500 rpm 138 bbl/min at 1000 rpm	Cap. Tank/time 649 bbls/20 min 32.45 bbl/min Or 5.192 m ³ /min	bbl/min m ³ /min
7	Blender Turbin Agitator	Cap. 75-90 rev/min Input 90 rev/min	rev/min
C	Direct Mixing and Discharge	Req. 14 bbl/min Design (SF = 1.5) Rate 21 bbl/min Or~ 3.35 m³/min	bbl/min m ³ /min
8	Suction Centrifugal Pump	≥ 3.35 m ³ /min	m ³ /min
9	Discharge Centrifugal Pump	≥ 3.35 m ³ /min	m ³ /min
10	Blender Turbin Agitator	Cap. 75-90 rev/min Input 90 rev/min	rev/min

3.2 Desain System

Before the Design System it is necessary to perform the manufacture of the block diagrams and P & ID's draft preliminary calculations needs head loss and the need for cooling equipment.

3.2.1 Blok Diagram

Block Diagram is a chart / diagram explaining the operation and the equipment used.




Figure 4. Blok Diagram Operasional and Equipment

3.2.2 P & ID (Piping and Instrument Diagram)

Piping and Instrument Diagrams (P & ID) is designed in accordance with the Block Diagram. Where this diagram will be the reference for the calculation of

required equipment and instrument both specifications, the type and number of units required.




Figure 5. Piping and Instrument Diagram (P&ID)

3.3 Calculation System

3.3.1 Calculation of Unit Head and RPM User

The need for pumps (User Units) in accordance with the operational needs (offshore operation) needs to be in accordance with the previous calculation data that has

been calculated and designed. Because there are changes, which include changes in the needs of Q (flow rate) and the Head of each pump of the conditions existing before the calculation of the adjustment.

TABLE 3.
 CALCULATION ADJUSTMENT DEBIT AND HEAD PUMPS

No	Equipment User	Qsp. (m ³ /min)	Hsp. (psi)	Qreq. (m ³ /min)	Hreq. (psi)
1	Suction centrifugal Pump	15	26	5.2	Cal.
2	Discharge centrifugal pump	22	15	5.2	15
3	Sand Screw	No adjustment (Rotated)			
4	Tub Agitator	No adjustment (Rotated blend)			
5	LA Pump	Accordance Unit			
6	Dry Additive	Accordance Unit			

From the table above it can be seen that the two pump units, the number 1 and 2 should be an adjustment Flow rate and the Head, this adjustment is done by a decrease in **3.3.2 RPM Motor Hydraulic Adjustment Calculation** Because no adjustment Flow rate (Q) and Head accordance with the operational condition then this will

RPM units according to the catalog specification unit / reference.

also affect the speed (RPM) on the hydraulic motor unit that is connected directly to the pump (Direct Driver).

TABLE 4.
 CALCULATION OF ADJUSTING THE RPM MOTOR HYDRAULIC

No	Pump Unit User	Motor Unit	RPMsp.	RPMreq.
1	Suction centrifugal Pump	Parker 9.15 CIR	1250	720
2	Discharge centrifugal pump	Rexroth 30.51 CIR	1000	900
3	Sand Screw 2	Eaton 45.76 CIR	350	350
4	Sand Screw 1	Eaton 36.74 CIR	400	400
5	Tub Agitator	Charlynn 40.6 CIR	150	150
6	LA 1	Parker 1.69 CIR	600	600
7	LA 2	Parker 2.54 CIR	600	600
8	Dry Additive 1	Rexroth 1.0 CIR	180	180
9	Dry Additive 2	Rexroth 1.0 CIR	180	180

3.3.3 Pipe diameter calculation unit User

Based on previous calculation, the calculation of the diameter of the pipe can be done.

TABLE 5.
 DATA FLOW RATE (Q) X RPM

No	Pump Unit	Q x 10 ⁻⁵ (m ³ /rev)	Rpm	Q x 10 ⁻³ (m ³ /s)
1	Suction centrifugal Pump	14.64	720	1.7568
2	Discharge centrifugal pump	48.816	900	7.3224
3	Sand Screw 2	73.216	350	4.2709
4	Sand Screw 1	58.784	400	3.9189
5	Tub Agitator	64.96	150	1.6240
6	LA 1	2.704	600	0.2704
7	LA 2	4.064	600	0.4064
8	Dry Additive 1	1.6	180	0.0480
9	Dry Additive 2	1.6	180	0.0480

From the Data Flow Rate (Q) the above table it can be calculated diameter of the pipe using the formula:

$$d_{Disch.} = \sqrt[0.5]{\frac{4Q}{\pi V}}$$

Where :

Q = Flow rate, 4.8, m³/s

V = Flow Velocity

Rekomendation flow velocity :

3.3.4 Pipe diameter calculation Hydarulic Main Pump
 Where the main hydraulic pump to supply to a hydraulic motor driver using one pump driven Electric Motor. Due to a series of pipeline pump as paralalel, then Q for this pipeline is the total of Q entire lifeline.

$$Q_{t1} = Q_{suct. centr.} + Q_{disch. centr.} + Q_{sand screw1} + Q_{sand screw2} + Q_{agitator} + Q_{la1} + Q_{la2} + Q_{dry add.1} + Q_{dry add.2}$$

So the result $Q_{t1} = 0.01967 \text{ m}^3/\text{s}$ or $70.79 \text{ m}^3/\text{h}$
 Pipe as needed :

$$d_{Disch.} = \sqrt[0.5]{\frac{4Q}{\pi V}}$$

$$d_{Disch.} = \sqrt[0.5]{\frac{4 \times 0.01976}{\pi \times 6}}$$

So the diameter = 64.62 mm or 2.54 inch
 use Pipe Diameter 2½” Inch Standart ANSI

1. Velocity of pressure lines = 7 – 20 ft/sec or 2.13 – 6.1 m/s

2. Velocity of suction lines = 2 – 5 ft/sec or 0.61 – 1.5 m/s

using V = 6 m/s

so that each Unit Discharge Pipe Users can be determined using ANSI Standard Pipe

3.3.5 Pipe Material Calculation and Minimum Thickness

Pressure / high pressure 5070 psi in accordance with the specifications Pressure Control Valve to be used and in accordance with the specifications Hydraulic Motor.

Operation pressure = 5070 Psi

Using the Reference Year ASME B.31. In 2012 we can see the minimum thickness of each pipe to be used.

With Formula Lame's or Barlow's, the minimum thickness is as follows:

$$Thickness = \frac{PD}{2S}$$

Where ;

t = thickness, in inch

P = Design pressure in psi

D = Outside Diameter Pipa, inch

S = Allowable stress, psi

Grade material used is in accordance with ASME B31 or SAE standards as recommended material.

Using material no.2 = Steel C-1021

So that the minimum thickness calculation is as follows :

TABLE 6.
THE CALCULATION OF THE MINIMUM THICKNESS OF THE PIPE AND SCHEDULE

No	Pump Unit	Ø Pipe ANSI	Min. thk (in.)	Min. thk (mm)	Sch. ANSI
1	Suction centrifugal Pump	1 "	0.17	4.29	80
2	Discharge centrifugal pump	1½ "	0.25	6.44	160
3	Sand Screw 2	1¼"	0.15	3.81	80
4	Sand Screw 1	1¼"	0.15	3.81	80
5	Tub Agitator	1 "	0.12	3.05	80
6	LA 1	½ "	0.05	1.27	80
7	LA 2	½ "	0.05	1.27	80
8	Dry Additive 1	½ "	0.05	1.27	80
9	Dry Additive 2	½ "	0.05	1.27	80
10	Main PP Q1	2½ "	0.42	10.73	160S
11	Main PP Q2a	2½ "	0.42	10.73	160S
12	Main PP Q2b	½ "	0.05	1.27	80

3.3.6 Calculations Head Main Pump

3.3.6.1 Specifications hydraulic oil used

Brand	= Mobile Exxon
Type	= Mobile EAL 32
Colour	= ISO 2049 : 1.5
Viscosity, ASTM D445	
Cst at 40 ° C	= 32
Cst at 100 ° C	= 7
Viscosity Index, ASTM D2270	= 189
Pour Point °C, ASTM D97	= - 39°C
Flash Point °C, ASTM D92	= 248°C
Density at 15°C/kg/l,	
ASTM D4052	= 911

Data from Exxon Hydraulic Oil Online Catalog

3.2.5.2 Calculation of Pressure Head

Where the Main Hydraulic Pump for supply to a hydraulic motor driver using one pump driven Parent Electric Motors.

Due to a series of pipeline pump server as paralalel then Head to Head this pipeline is needed most

3.3.7 Main Hydraulic Pump

From the data above calculation can resumed as follows

Q	= 70.79 m ³ /h or 1179.83 l/min
Head / Pressure	= 5890 psi – 406 Bar

So choosed Hydraulic Electric Mover Pump :

Brand	= Uraca
Type	= Plunger Pump – P5 80
Pmax	= 1120 kW
Eff.	= 0.92

3.3.8 Requirement of Electric Motor

• Power of Fluids (Pimp_{sa})

Water Power / Pump (P_w) is the energy effectively accepted by the fluid from the pump per unit time.

$$P_w = \gamma QH$$

Where :

$$Q = \text{flow rate, } 0.01966 \text{ m}^3/\text{s}$$

H = head / pressure, 4058.605 m

γ = light of fluida / vol., 911 kg/m³

❖ So P_w = 72690.67 watt or 726.91 kW

• Shaft Power (Ps)

Shaft power is the power required to drive a pump. where as follows :

$$P_s = P_w / \eta_P$$

Where :

P_w = Power of fluida, 726.91 kW

H_p = Eff. Pump, 0.92

❖ So P_s = 790.12 kW

• Power of Nominal (Pm)

Nominal power is power derived from the transmission efficiency and the efficiency of the motor itself. Where P_m follows

$$P_m = \frac{P_s(1 + \alpha)}{\eta_t}$$

Where :

P_m = Power Nominal, kW

P_s = Power Shaft, 790.12 kW

α = Additional factor, 0.15

Due to Transmission used direct coupling so $\eta_t = 1$

❖ So P_m = [790.12(1+0.15) / 1]

$$= 908.638 \text{ kW}$$

Chosed Electric Motor :

Brand = Loher - Motors

Type = IP5 8 Pole 50 Hz 450 Frame

Pmax = 950 kW

Eff. = 0.92

3.3.9 Requirement Reservoir Tank

Rekomendation of volume Reservoir tank is

$$\begin{aligned} \text{Vol.} &= (3-5) \times Q \text{ at m}^3/\text{min} + 10\% \text{ for aerating space} \\ &= 3 \times Q (\text{m}^3/\text{min}) \times 110\% \\ &= 3 \times 1.180 \times 1.1 \\ &= 3.894 \sim 4 \text{ m}^3 \end{aligned}$$

❖ So the Volume of Reservoir Tank = 4 m³

3.3.10 Requirement of Cooler

Cooling in instaaltion unit power pack aims to keep the hydraulic oil temperature remains in standard (40-50°C).

• Cooler Calculation

$$Q = m C \Delta T / t \times 60$$

Where :

ΔT = Diff. temperature, 50 – 40 = 10°C

C = Specific heat, 0.497 kCal/kg°C

m = mass flow rate, 17.91 kg/s

So $Q = 17.91 \times 0.497 \times 10 / 1 \times 60$
 = 1.484 kCal/s or 6.2 kW or 5342.4 kCal/h

• Requirement of surface area HO Cooler

$$A = \text{Heat Dissipation} / (K \times \text{LMTD})$$

Where :

HD = Heat Dissipation, 5342.4 kCal/h

K = Heat transfer coef. 260 kCal/m².h. °C

LMTD = Log Mean Temperature Diff.

$$\text{LMTD} = [(T1-t2)-(T2-t1)]/\text{Log}[(T1-t2)/(T2-t1)]$$

T_{water cooler}

t1 = 32 °C ; t2 = 40 °C

T_{heat fluid/oil}

T1 = 50 °C ; T2 = 40 °C

So LMTD = 20.64 °C

So $A = 0.9955 \text{ m}^2$

❖

Chooed Cooler :

Brand = Aalborg – Vesta MX

Type = MX 10 - Tube

Pmax = Up to 10 kW

• Requierement of Cooler Pump

a. Calculation Centrifugal Pump Cooler Pipe

The calculation is performed with references from the Book of Pumps and Compressors, Ir. Sularso and Dr. H. Tahara

Velocity of fluid design = 3 m/s

Formula :

$$d_{\text{Disch.}} = \sqrt[0.5]{\frac{4Q}{\pi V}}$$

Where :

Mass flow rate = 17.9 kg/s so $Q = (17.9/1000)\text{m}^3/\text{s}$

Q = Flow rate, 0.0179 m³/s

V = velocity, 3 m/s

So D discharge = 0.087 m or 3.5 inch

Using Pipe Standart ANSI 3.5”sch 40

OD = 4.000 in

ID = 3.548 in

Thk = 0.226 in

Material Carbon Steel with Galvanis Surface

b. Calculation Head Centrifugal Pump Cooler

Head Pump Calculation

$$H_{\text{total}} = H_s + \Delta H_p + H_v + H_{\text{loss}}$$

Where :

H_s = Head Statis, Length suction well with discharge pipe

= 1.1 m

ΔH_p = Diff head pressure, (P_{disc} – P_{suction})/ ρg

= 0 m, pressure at suction and discharge

typically

H_v = head speed output, (V²_{disch} – V²_{suct})/2g

= 0, velocity di suction and discharge same

Head Loss = H_{loss} disch + H_{loss} suct.

Total od head (H_{tot}) = H_s + H_p + H_v + H_{loss}

= 1.1 + 0 + 0 + 3.3

= 4.4 m

❖ From calculation :

$Q = 0.0179 \text{ m}^3/\text{s}$ or 10.74 l/min or 64.44 m³/h

Head / Pressure = 4.4 m head or 44 bar

Chooed Centrifugal Pump :

Brand = Sili Pump

Type = Centrifugal Pump – 100CLZ-17A

Qmax = 72 m³/h

Hmax = 18 m

Pmax = 7.5 kW

c. Calculation of Volume Water Cooler

Calculations were performed to determine the needs cooler where it is fresh water that will be placed on the tank 3CP

3.4 Calculation of Instalation Cost

The calculation of costs includes the cost of the work, the cost of materials and equipment, the cost of consultants and supervision, as well as administrative costs.

TABLE 7.
COST CALCULATION

No	Items	Price (Rp)
1	Instalation	43.800.000,00
2	Material and Equipment	335.750.000,00
3	Consultan and Supervisi (10%)	37.955.000,00
4	Administration and Tax (15%)	56.932.500,00
Grand Total		474.437.500,00

TABLE 8.
MAIN EQUIPMENT

No	Unit	Spec.
1	Main Hydraulic Pump	
	Brand : Uraca	P : 950 kW
	Type : Plunger Pump – P5 80	Q : 1204 l/min
		H : 450 bar
2	Electric Motor	
	Brand : Loher Motors	P : 950 kW
	Type : IP5 8 Pole 50 Hz 450 Frame	Eff. : 0.92
3	Reservoir Tank	4 m ³
4	Cooler	
	Brand : Aalborg – Vesta MX	P : Up 10 kW
	Type : MX 10 - Tube	
5	Centrifug. Cooler Pump	
	Brand : SILI - Pump	P : 7.5 kW
	Type : 100CLZ – 17A	Q : 72 m ³ /h
		H : 18 m
6	Hydraulic Oil	
	Brand : Mobile Exxon	Cst40° : 32
	Type : Mobile EAL 32	Cst100° : 7
7	Media Cooler - freshwater	3 m ³

IV CONCLUSION

From Analysis, Design and Calculation System that has been done it can be concluded that for this Final:

1. Design and Analysis Calculation starts include:

- Operational Requirement or Performance Unit in accordance with the operational needs of the Mahakam Delta Offshore Blocks
- System Design: Block Diagram, P & ID diagrams in accordance with Annex Figure
- Calculation System includes :
 - a. Performance adjustment calculation unit
 - b. RPM adjustment calculation
 - c. Calculation of diameter and thickness
 - d. Calculation and selection of equipment Main

2. Design Layout and Detail Image refers to the General arrangement Stimulation Vessel - SSB where the main equipment, Power pack unit installed at the location Compartemen above the double bottom, the compartment 2CP or between frames 6 s / d frame 9. While Blender Pack Unit (High rate blender) installed on location in the Main deck, frame between 19 s / d frame 23

3. Calculation of installation costs are modest result for Rp. 474,437,500.00

REFERENCES

- [1] Fracturing Equipment “High Rate Blender Operating Manual” , Halliburton World. 2014.
- [2] Tim Lab.Mesflu, “Modul Praktikum Mesin Fluida – Pnumatis dan Hidrolis” 2011 rev.1
- [3] TDI (Texas Department of Inspection) “Hydraulic Power Unit”TDI Bulletin Volume 1, Issued 2
- [4] Production Enhancement Department “Stimulation Vessel - SSB” , Halliburton World. 2006.
- [5] Document Of Service (DOS) Total Indonesia PK-J9. 2015
- [6] Sularso. Pompa dan Kompresor. 1985
- [7] F.Brater, Ernes. Handbook of Hydraulic. 1996
- [8] Price List Equipment, <http://www.alibaba.com/html>